

**BOROUGH OF MANVILLE**  
**BUREAU OF FIRE PREVENTION**

325 NORTH MAIN STREET, MANVILLE, NJ 08835  
PHONE: (908) 725-9478 Ext. 112 • FAX: (908) 725-2471



**EMERGENCY LIGHTING/ EXIT SIGNS ANNUAL TESTING LOG**

YEAR \_\_\_\_\_

DATE	UNIT No.	Conditions (Working/Repairs Needed)	Comments (Condition of Repairs)	Technician

\*\*\* State law N.J.A.C. 5:70-3, 604.3.1.1 requires that emergency lighting, including exit signs shall be tested for the proper operation for a minimum of 30 seconds every month. An annual test shall be conducted for at least 1 hour.